



## MEASURES OF COEFFICIENT OF FRICTION

The following test was run by

### The NATIONAL INSTITUTE OF RESEARCH AND SECURITY (INRS)

To prevent workplace accidents and occupational diseases

Product	Base	Granulation	INRS Reference
<b>Steel sheet Agrain® Galva</b>	Steel Sheet	Angular iron particles	Minutes IET/09RI-270/HS December 2009

### Measures of coefficient of dynamic friction ( $\mu_d$ ) on steel sheet Agrain® Dur

Coefficient obtained
<b><math>\mu_d = 0.67^*</math></b>

\* 0,30 is the minimum value to qualify a flooring as "non-slip", according to the measurement protocol of INRS.

### Measures of coefficient of friction on steel sheet Agrain® Galva

**Test run in presence of a lubricating agent : mineral oil.**